

TO: ALL PLANHOLDERS
FROM: CARL L. COOK, P.E., PROJECT ENGINEER *clc*
PROJECT: MAPLETON CITY SECONDARY WATER SYSTEM, PHASE 1
DATE: APRIL 25, 2011
SUBJECT: ADDENDUM NO. 3

NOTE CHANGE IN BID DATE.

ADDENDUM NO. 3 for the Mapleton City Secondary Water System, Phase 1 has been issued and is attached for your information in preparing your bid for the PROJECT. The ADDENDUM consists of 6 items with no attachments. The Addendum will also be posted on the Mapleton City website at mapleton.org.

Receipt of ADDENDUM NO. 3 must be acknowledged in Paragraph 4.1 ADDENDA of Document 00 41 00 BID FORM which will be submitted with your bid. Failure to acknowledge receipt of this Addendum will cause the bid to be considered Non-Responsive.

**MAPLETON CITY SECONDARY WATER SYSTEM, PHASE 1
ADDENDUM NO. 3**

Date: April 25, 2011

Bid Date: April 28, 2011 – NOTE CHANGE OF BID DATE

Bid Time: 2:00 p.m. MDT

Addendum Items:

1. Bid Date and Time: THE BID DATE IS CHANGED TO APRIL 28, 2011 AT 2:00 P.M. MDT. The place of the bid opening is unchanged. Sealed bids will be received at the Mapleton City Offices at 125 West Community Center Way, Mapleton, Utah 84664.
2. SECTION 33 11 00 – WATER DISTRIBUTION AND TRANSMISSION is hereby modified as follows:
 - 2.1 PIPES AND FITTINGS
 - E. All pipe used for secondary water shall be as follows:
 1. Polyvinyl Chloride (PVC):
 - a. C-900 SDR 18 for pipe 12” in diameter and less.
 - b. C-905 SDR 18 for pipe 16” in diameter.
 2. Ductile Iron Pipe
 - a. Pressure Class 350 for pipe 12” in diameter and less.
 - b. Pressure Class 250 for pipe 14” and greater.
 3. The requirement to use ductile iron pipe for 20” and 24” pipe on the project is unchanged.
3. BID ITEM NO. 92 – PRECAST CONCRETE STORM DRAIN MANHOLE WITH FRAME AND COVER. The manhole shall be Type C (60” diameter) as shown on APWA Standard Plan No. 341.
4. SECTION 33 12 33 – WATER METER Part 2.1.C.12 is hereby modified as follows:
 12. The detector portion of the meter shall be placed in a NEMA 6 enclosure. The amplifier shall be remotely located within the vault in a NEMA 4 enclosure with 15 feet of cable.
5. SECTION 01 45 00 – QUALITY CONTROL is hereby modified to include the following: Quality Control Acceptance testing on the project will be provided by the OWNER.
6. SECTION 22 11 23 WATER PUMP: Amend this Section as follows:

Paragraph 2.8.C: American Marsh and National brand pumps are considered as an approved equal subject to the design requirements specified.

END OF ADDENDUM